


NOTES

1. MADE TO AS1170-1 AS2634 AS1546
2. MADE FROM 8MM ISO NPG FIBERGLASS
3. TANK IS DESIGNED FOR BELOW GROUND INSTALLATION ONLY
3. SUITABLE FOR OIL WATER SEPARATORS IN WASH BAYS
4. AVAILABLE WITH GALVANISED GRATE OR GATIC LID TO CLASS D
5. SILT TRAP, SUCTION PIPE, ELECTRICAL CONDUIT & FLOAT SWITCH SOLD SEPARATELY
6. PUMP SUCTION LINE TO BE PVC PRESSURE PIPE & SIZED TO SUIT PUMP
7. INSTALL CHECK VALVE IN SUCTION LINE ONLY FOR PROGRESSIVE CAVITY (MONO) PUMPS.
8. DO NOT INSTALL CHECK VALVE IN SUCTION LINE FOR DIAPHRAGM PUMPS
9. ENSURE SUCTION LINE FINISHES IS AT LEAST 200mm OFF THE BOTTOM OF THE PIT
10. ENSURE PUMP START LEVEL IS BELOW INLET PIPE LEVEL

Itemref	Quantity	Title/Name, designation, material, dimension etc			Article No./Reference		
Designed by PE	Checked by DP	Approved by - date GW - 7/2/06	File name FG750PIT	Date 7/2/07	Scale 1:20		
 INDUSTRIAL SEPARATION SYSTEMS Unit 4 / 181 -187 Taren Point Road, TAREN POINT. NSW. 2229 Ph: (02) 9524 6654 Fax: (02) 9524 6685 Web: www.issproject.com.au			750 LITRE FIBREGLASS COLLECTION WELL				
			ISS-ACC-006		Revision B	Sheet 1/1	